

ANALYTICAL LABORATORIES, INC.  
P.O. Box 319  
CHELFONT, PA 18914  
(215) 723-6466

SAMPLE ANALYSIS REPORT

Customer: Lansdale Ice  
2080 Detweiler Rd.  
Harleysville, Pa 19438  
  
Attn: Vinny 215/361-1111  
Fax :

Sample number: 6442-08  
Date sampled : 08/01/08  
Time sampled : N/A  
Date received: 08/01/08  
Sampled by : Customer

Sample source: Ice - Lot #214(8lb. bag)

ANALYTICAL RESULTS

Water Safety Classification: No coliform bacteria were detected. Therefore, the water supply, at the time of sampling, meets the DEP and EPA drinking water standards for this parameter.

<u>Parameter</u>	<u>MCL</u>	<u>Result</u>
Coliform Bacteria, counts/100 ml	< 1.	< 1
Noncoliform Bacteria, counts/100 ml		< 1
Standard Plate Count, counts/100 ml	500	< 1

All results which are outside the "Maximum Contaminant Level" (MCL) established under the "Safe Drinking Water Act" are marked by asterisks (\*\*).

Symbol key:  
< - less than  
+ - action level  
mg/l - milligram/liter

PA DEP #09-332

*AW. K*

Geoff W. Kinka